SOCOTEC UK Limited
139 Summerlee Street
Queenslie Industrial Estate
Glasgow
G33 4DB
Telephone: +44(0) 141 774 6271
kenny.mcintosh@socotec.co.uk

TEST REPORT

Skid Resistance - Pendulum Method

BS 7976-2:2002: +A1:2013

Client: Robeslee Concrete
Southbank Road
Kirkintilloch
G66 1UA

Report No: G29085
Our Ref: SCO25-00833-S003

Report Date: 06/05/2025

Date Tested: 25/04/2025

Attention: Steven Black

Tested By: SOCOTEC UK Limited, Glasgow

Site: Southbank Road, Kirkintilloch

General Information:

Pendulum Equipment No: E8161
Test Area: Test Length 1.09m, step
Material (if known): Concrete

Slider Rubber Type: 4S
Slider Rubber No: E60339 2025

Test Results

Test Location / Direction of Test	Surface Moisture	Surface Texture	Surface Condition	Surface Temp (ºC)	Mean PTV
Yard Step, Test 3-1A (Length)	Dry	Smooth	As found	21	**68**
Yard Step, Test 3-1B (Length)	Wet	Smooth	As found	21	**55**
Yard Step, Test 3-2A (Breadth)	Dry	Smooth	As found	21	**67**
Yard Step, Test 3-2B (Breadth)	Wet	Smooth	As found	21	**53**
Yard Step, Test 3-3A (45°)	Dry	Smooth	As found	21	**68**
Yard Step, Test 3-3B (45°)	Wet	Smooth	As found	21	**55**

Remarks:

Signed:

Kenny McIntosh – Operations Manager
for and on behalf of SOCOTEC UK Limited

The results relate to the items tested only.
This test report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.
SOCOTEC UK Limited, Reg Office: SOCOTEC House, Bretby Business Park, Ashby Road, Burton upon Trent, DE15 0YZ. Incorporated in England: 02880501.